

BACNET INTERFACE TST6601



BACnet Interface for TKT66xxC central battery units

Product Code	TST6601
Customs Code	85044090
GTIN Code	6438045008653
ETIM Product Class	EC001099

ONE OR MORE OF THESE IS ALSO REQUIRED:

ADDRESSABLE 230 V CENTRAL BATTERY SYSTEMS



Product Code	Nominal Supply Voltage	Number of Output Circuits	Max Load of Circuits (VA)
TKT6608C	1~ N/PE 220-240 VAC, 50/60 Hz	8 x 350 VA / W	
TKT6616C	1~ N/PE 220-240 VAC, 50/60 Hz	16 x 350 VA / W	
TKT6624C	1~ N/PE 220-240 VAC, 50/60 Hz	24 x 350 VA / W	
TKT6608CF	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	8 x 350 VA / W	
TKT6616CF	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	16 x 350 VA / W	
TKT6624CF	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	24 x 350 VA / W	
TKT6608CFP	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	8 x 350 VA / W	
TKT6616CFP	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	16 x 350 VA / W	
TKT6624CFP	3~ N/PE 220-240/380-415 VAC, 50/60 Hz	24 x 350 VA / W	

We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: May 03, 2024 | Source:
www.teknoware.com/en/emergency-lighting/bacnet-interface-tst6601

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com



We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: May 03, 2024 | Source:
www.teknoware.com/en/emergency-lighting/bacnet-interface-tst6601

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com

