



## **CERTIFICATE FI 29558**

Our Ref. 274642-1

**Product** 

**Emergency luminaire** 

Type

**TWT8151WK** 

Trade mark

Teknoware

Certificate Holder /

Manufacturer

Teknoware Oy Ilmarisentie 8

FI-15200 LAHTI, FINLAND

**Technical information** 

DB-4,2W/6,5VA; 220-240V; 50/60Hz; class II; IP44; ta 50°C; emergency class Z1

Other information

Centrally supplied maintained luminaire for emergency lighting

The product is certified according to the following standard(s)

EN 60598-2-22:2014 EN 60598-1:2015

Validity

This certificate is valid until 23 May 2021 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information

The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Date of issue

23 May 2016

SGS Fimko Ltd

Signature

Kari Vesterinen

Product Line Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <a href="http://www.sgs.fi/en/Terms-and-Conditions.aspx">http://www.sgs.fi/en/Terms-and-Conditions.aspx</a>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



Appendix to Certificate: 29558

Manufacturing sites

Teknoware Oy Ilmarisentie 8 FI-15200 LAHTI, FINLAND

**Additional information** 

The product has certificate CB FI 9233 issued by SGS Fimko Ltd in accordance with the CB system.



As shown in the Test Report(s) No(s): 274642-1A